

INSTALLATION INSTRUCTIONS


IMPORTANT SAFEGUARDS

When using electrical equipment, basic safety precautions should always be followed including the following:





READ AND FOLLOW ALL SAFETY INSTRUCTIONS

1. To reduce the risk of electrical shock, turn off power supply before installation or servicing.
2. This luminaire must be installed in accordance with the NEC or your local electrical code. If you are not familiar with these codes and requirements, consult a qualified electrician.
3. DO NOT lift luminaire by the supply cord.

SAVE THESE INSTRUCTIONS FOR FUTURE REFERENCE



TO INSTALL:



LUMINAIRE INSTALLATION

STEP 1:

Using customer supplied hardware attach mounting plate to ceiling with the arrow on the underside of the Mounting Plate directed parallel to vehicle traffic. Ensure that the ceiling is capable of supporting the weight of the luminaire. See **Figure 1 and 2.**

STEP 2:

Bring luminaire up to Mounting Plate, rotate luminaire until the arrow on the inside of the Mounting Plate points to the recessed area nearest to the latch on the luminaire. See **Figure 3.**

STEP 3:


Attach luminaire to the Mounting Plate by pressing up on the luminaire until the slots on the Mounting Plate engage with the clips on the luminaire and rotate until latch locks securely. See **Figure 4.**

NOTE: May require extra pressure on Mounting Plate to engage luminaire clips into slots.

NOTE: If the Mounting Plate slots become deformed during installation, slightly reopen the slots back up using a screwdriver to ensure proper install of luminaire.

STEP 4:

Install a suitable Listed liquid tight cord strain relief bushing in the customer supplied junction box, and feed the luminaire's supply cord through it.



STEP 5:

Connect the cord to the supply wiring per the “**Electrical Connections**” section.

STEP 6:

Lightly pull on the luminaire to verify luminaire is securely mounted.

FIXTURE SERVICING AND MAINTENANCE

STEP 1:

If luminaire needs to be removed, fully loosen the tamperproof screw and slide out the latch. Then, rotate luminaire to disengage from Mounting Plate. See **Figure 5**.

STEP 2:

To re-install luminaire, engage and tighten the latch’s tamperproof screw and follow Step 1-4 in “Luminaire Installation” section above.

ELECTRICAL CONNECTIONS

STEP 1:

Make the following Electrical Connections :

- a. For 120/277V connect the black fixture lead to the voltage supply position of the junction box (Hot 1 for 208/240V wiring).
- b. For 120/277V Connect the white fixture lead to the neutral supply position of the junction box (Hot 2 for 208/240V wiring).
- c. Connect the green or green/yellow ground lead to the green wire position of the junction box.
- d. If Dimming is an option; connect the violet dimming positive lead to the supply dimming positive lead.
- e. If Dimming is an option; connect the grey dimming negative lead to the supply dimming negative lead.

